

1. Unique identification of product	Firetect® Acrylic sealant	
2. Intended use	service closure for structural (expansion) joints and openings for pipe + cable penetrations, to form a penetration seal in case of fire to reinstate the fire resistance of: - standard flexible walls \geq 100mm - standard rigid walls \geq 100mm - standard rigid floors \geq 150mm	
3. Manufacturer	KLF Building Products BV Techniekweg 11, 4207 HC Gorinchem, The Netherlands	
4. Authorised representative	not applicable	
5. System of AVCP	System 1	
6a. Harmonised standard	not applicable	
Notified body	not applicable	
6b. European Assessment Document (EAD)	350454-00-1104	350141-00-1106
European Technical Assessment (ETA)	ETA-14/0273	ETA-15/0630
Certificate of Constancy of Performance	0960-CPR-SKGIKOB.011133.01.NL	0960-CPR-SKGIKOB.011137.01.NL
Technical Assessment Body (TAB)	SKG-IKOB	SKG-IKOB
Identification notified body	No. 0960	No. 0960
7. Declared performances		
basic requirements	characteristics	performances
BWR 1 Mechanical resistance + stability		not relevant
BWR 2 Safety in case of fire		
EN 13501-1	reaction to fire	Class F
EN 13501-2	resistance to fire	per tested assembly; EI 30 up to EI 240, + Sa - S200; see ANNEX BWR2 + ANNEX A
	field of application	
BWR 3 Hygiene, health + environment		IA1, S/W3
EAD ...-1104, §2.2.3 + EAD ...-1106, §2.2.4	air permeability	npd
EAD ...-1104, §2.2.4 + EAD ...-1106, §2.2.5	water permeability	npd
EAD ...-1104, §2.2.5 + EAD ...-1106, §2.2.3	content, emission and/or release of dangerous substances	not dangerous under Regulation 1272/2008 in compliance with CLP regulations
BWR 4 Safety + accessibility in use		
EAD ...-1104, §2.2.6 + EAD ...-1106, §2.2.6	mechanical resistance + stability	npd
EAD ...-1104, §2.2.7 + EAD ...-1106, §2.2.7	resistance to impact / movement	npd
EAD 350141-00-1106, §2.2.8	adhesion	passed
EAD ...-1104, §2.2.9 + EAD ...-1106, §2.2.12	durability	Z ₂ (internal use)
EAD 350141-00-1106, §2.2.13	movement capability	max. 7,5% SA (self-adhering)
BWR 5 Protection against noise		
EAD 350454-00-1104, §2.2.10	airborne sound insulation	R _{s,w} = 44 dB up to 53 dB
	field of application	see ANNEX B
BWR 6 Energy economy + heat retention		
EAD 350454-00-1104, §2.2.11	thermal properties	npd
EAD 350454-00-1104, §2.2.12	water vapour permeability	npd
General aspects relation to fitness for use		
EAD 350454-00-1104, §1.2.2	assumed working life for the intended use	10 years
8. Specific Technical Documentation	not applicable	npd= no performance determined

The performances of the products identified are in conformity with the declared performances. This declaration of performance is issued, in accordance with Regulation 305/2011, under the sole responsibility of the manufacturer.

Signed for and on behalf of the manufacturer in Gorinchem dated 18-10-2019 by C. Buikema



field of application (FoA)	Firetect® Acrylic sealant
	tested and certified by ETA-14/0273 + ETA-15/0630; fire resistance performances and assembly methods for uses in:

constructive element ¹⁾

fire rated walls acc. EN 1363-1	- flexible wall ≥100mm; metal or timber studs, plaster board type A + wall insulation - rigid wall ≥100mm: blockwork/concrete/masonry, density ≥ 600 kg/m ³ - rigid wall ≥150mm: blockwork/concrete/masonry, density ≥ 600 kg/m ³
fire rated floors acc. EN 1363-1	- rigid floor ≥150mm: (aerated) concrete, density ≥ 600 kg/m ³

¹⁾ the constructive element must be classified acc. EN 13501-2 for the required fire resistance period

fire resistance		smoke control acc. EN 1634-3 smoke leakage control: Sa - S200
field of application:	acc. EN 13501-2 / 1366-3	
EI 30 up to EI 240: Acrylic sealant	structural openings for pipe + cable penetrations: ²⁾	
- PE/PVC	≤ Ø50mm	also in PA board
- aluPE-X	≤ Ø75mm	also with pipe insulation
- PE-Xa	≤ Ø32 (54) mm	
- copper	≤ Ø54mm	also with pipe insulation + PA board
- steel	≤ Ø219mm	also with pipe insulation + PA board
- cable trays incl. cable ladders + wire mesh	≤ 600x1200mm +25% in walls ≤ 1000x1200 mm / 600x5000mm in floors	coat back is not required coat back is not required
- cable bundles	≤ Ø121mm	also in PA board
field of application:	acc. EN 13501-2 / 1366-4	
EI 60 up to EI 120: Acrylic sealant	structural joints:	
- linear joints	≤ 50mm	horizontal orientation, incl. abutting walls vertical orientation

²⁾ support services; support distance: see principle detail

environmental performances	BREEAM	LEED	VOC France	EN 717-1§	EMICODE	M1	Indoor Air
example protocols, click for full list	<input checked="" type="checkbox"/>		A+	E1	EC1 PLUS		Comfort GOLD

fasteners	not applicable fasten glass wool or rock wool individually (not wrapped!) with steel wire	see TDS
------------------	--	---------

finish	avoid contact with water during curing	see TDS
---------------	--	---------

product information	
Product certification by DoP; more info on certification of CE building products through ETA at firetect.eu/certification	
- full DoP version: declaration of performance + ANNEX BWR2 + ANNEX A + ANNEX B; upon request	
- web DoP version: declaration of performance + ANNEX BWR2; other info can be downloaded at firetect.eu/download	
- FoA charts; suitable products per type of fireseal + EI performance + product / joint details	
- TDS: general directions for use + product specs	
Consult firetect.eu/download for updated versions; product development + fire tests are ongoing processes at KLF. Contact KLF for other EI requirements and (non)standard or complex site requirements; mail info@klf.nl	
 	