

1. Unique identification of product	Firetect® Flex strip	
2. Intended use	service closure for structural (expansion) joints, to form a penetration seal in case of fire to reinstate the fire resistance of: - standard flexible walls \geq 100mm - standard rigid walls \geq 100mm	
3. Manufacturer	KLF Building Products BV Techniekweg 11, 4207 HC Gorinchem, The Netherlands	
4. Authorised representative	not applicable	
5. System of AVCP	System 1	
6a. Harmonised standard	not applicable	
Notified body	not applicable	
6b. European Assessment Document (EAD)	350141-00-1106	
European Technical Assessment (ETA)	ETA-15/0630	
Certificate of Constancy of Performance	0960-CPR-SKGIKOB.011137.01.NL	
Technical Assessment Body (TAB)	SKG-IKOB	
Identification notified body	No. 0960	
7. Declared performances		
basic requirements	characteristics	performances
BWR 1 Mechanical resistance + stability		not relevant
BWR 2 Safety in case of fire		
EN 13501-1	reaction to fire	Class E
EN 13501-2	resistance to fire	per tested assembly; EI 30 up to EI 240, field of application see ANNEX BWR2 + ANNEX A
BWR 3 Hygiene, health + environment		IA1, S/W3
EAD 350141-00-1106, §2.2.4	air permeability	npd
EAD 350141-00-1106, §2.2.5	water permeability	npd
EAD 350141-00-1106, §2.2.3	content, emission and/or release of dangerous substances	not dangerous under Regulation in compliance with CLP regulations
BWR 4 Safety + accessibility in use		
EAD 350141-00-1106, §2.2.6	mechanical resistance + stability	npd
EAD 350141-00-1106, §2.2.7	resistance to impact / movement	npd
EAD 350141-00-1106, §2.2.8	adhesion	passed
EAD 350141-00-1106, §2.2.12	durability	Z ₁ (internal use)
EAD 350141-00-1106, §2.2.13	movement capability	max. 25%, FF (friction-fixed)
EAD 350141-00-1106, §2.2.15	compression set	max. 40%
BWR 5 Protection against noise		
EAD 350141-00-1106, §2.2.9	airborne sound insulation	Rs,w = 40 dB up to 51 dB field of application see ANNEX B
BWR 6 Energy economy + heat retention		
EAD 350141-00-1106, §2.2.10	thermal insulation	npd
EAD 350141-00-1106, §2.2.11	water vapour permeability	npd
General aspects relation to fitness for use		
EAD 350141-00-1106, §1.2.2	assumed working life for the intended use	10 years
8. Specific Technical Documentation	not applicable	npd= no performance determined

The performances of the products identified are in conformity with the declared performances. This declaration of performance is issued, in accordance with Regulation 305/2011, under the sole responsibility of the manufacturer.

Signed for and on behalf of the manufacturer in Gorinchem dated 18-10-2019 by C. Buikema



field of application (FoA)	Firetect® Flex strip
	tested and certified by ETA-15/0630; fire resistance performances and assembly methods for uses in:

constructive element ¹⁾	
fire rated walls	
acc. EN 1363-1	- flexible wall ≥100mm; metal or timber studs, plaster board type A + wall insulation - rigid wall ≥100mm: blockwork/concrete/masonry, density ≥ 600 kg/m ³ - rigid wall ≥150mm: blockwork/concrete/masonry, density ≥ 600 kg/m ³
fire rated floors	
acc. EN 1363-1	- rigid floor ≥150mm: (aerated) concrete, density ≥ 600 kg/m ³
¹⁾ the constructive element must be classified acc. EN 13501-2 for the required fire resistance period	

fire resistance	
field of application:	acc. EN 13501-2 / 1366-4
EI 30 up to EI 240 : Flex strip	structural joints:
- linear joints	≤ 50mm
	adjacent joints in wall, orientation:
	- horizontal, incl. abutting floors
	- vertical
	adjacent joints in floor, orientation:
	- horizontal, incl. abutting walls

fasteners	not applicable	see TDS
------------------	----------------	---------

finish	seal remaining small gaps > 3mm with Acrylic or PA sealer	see TDS
---------------	---	---------

product information	
Product certification by DoP; more info on certification of CE building products through ETA at firetect.eu/certification	
- full DoP version: declaration of performance + ANNEX BWR2 + ANNEX A + ANNEX B; upon request	
- web DoP version: declaration of performance + ANNEX BWR2; other info can be downloaded at firetect.eu/download	
- FoA charts; suitable products per type of fireseal + EI performance + product / joint details	
- TDS: general directions for use + product specs	
Consult firetect.eu/download for updated versions; product development + fire tests are ongoing processes at KLF.	
Contact KLF for other EI requirements and (non)standard or complex site requirements; mail info@klf.nl	
 	