

## Ductwork in metal stud - principle configuration

0040

2

Fire Resistance Test In Accordance With EN 1366-3 / flex wall 100mm

Ductwork 500 x 500 mm

with 1500 mm LI Firetect PA board 1S 50 mm  
in 2x Firetect PA Board 1S 50 mm

**EI 60 minutes**

aperture 700 x 700 mm

and smoke seal Firetect Acrylic

C/U

