

PP-MD pipe in aerated concrete floor		P17.6.1
Fire Resistance Test In Accordance With EN 1366-3 / aerated concrete floor 150 mm		
Uponor Bottom Bend (silencer) + PP-MD pipe	with Firetect FMU on exposed side	EI 180 minutes
	and Firetect Mortar	
		U/C

