

# cable basket in aerated concrete floor

P17.6.6

Fire Resistance Test In Accordance With EN 1366-3 / aerated concrete floor 150 mm

cables + PP-R pipe  
insulated by 25 mm pipe insulation

with Firetect FMU collar on 1 side fastened  
with Firetect PA spirals,  
or Firetect Graphite on both sides;  
5 mm Acrylic around cables and basket.  
**No coat back!**

in 2x Firetect PA board 2S

U/C

