



tested property  
test method  
service no.

fire resistance  
EN 1366-3  
8-5-9

## aluPE-X pipes

### Acrylic sealant

service type <sup>1)</sup> dØ (mm)    s1 (mm)	pipe insulation min. 60 kg/m <sup>3</sup> eg Armallex	EI	constructive element <sup>2)</sup>	Firetect joint seal		application 1 or 2 sides	backing required	max. opening in construction	pipe end configuration	max. angle
				width	depth					
Ø16    2,0	-	EI 120	flexible walls ≥ 100 mm	5 mm	25 mm	2 sides	-	26mm	U/C + C/C	perpendicular + all angles between 90° and 45°
	synth. rubber 13mm	EI 120	rigid walls ≥ 150 mm	10 mm	25 mm	2 sides	-	62mm	U/C + C/C	
	13mm	EI 120	rigid floors ≥ 150 mm	10 mm	25 mm	2 sides	-	62 mm	U/C + C/C	
Ø25    2,5	-	EI 120	flexible walls ≥ 100 mm	10 mm	25 mm	2 sides	-	45 mm	U/C + C/C	perpendicular + all angles between 90° and 45°
	synth. rubber 13mm	EI 120	rigid walls ≥ 150 mm	10 mm	25 mm	2 sides	-	71 mm	U/C + C/C	
	13mm	EI 60	rigid walls ≥ 100 mm in FR mortar	10 mm	25 mm	2 sides	-	200x1000 mm	U/C + C/C	
	13mm	EI 120	rigid floors ≥ 150 mm	10 mm	25 mm	2 sides	-	71 mm	U/C + C/C	
Ø63    6.0	synth. rubber 13mm	EI 120	rigid walls ≥ 150 mm	10 mm	25 mm	2 sides	-	109 mm	U/C + C/C	perpendicular + all angles between 90° and 45°
	13mm	EI 60	rigid walls ≥ 100 mm in FR mortar	10 mm	25 mm	2 sides	-	200x1000 mm	U/C + C/C	
	13mm	EI 120	rigid floors ≥ 150 mm	10 mm	25 mm	2 sides	-	109 mm	U/C + C/C	
max. Ø75    7,5	synth. rubber 13mm	EI 120	rigid walls ≥ 150 mm	10 mm	25 mm	2 sides	-	121 mm	U/C + C/C	perpendicular + all angles between 90° and 45°
	13mm	EI 60	rigid walls ≥ 100 mm in FR mortar	10 mm	25 mm	2 sides	-	200x1000 mm	U/C + C/C	
	13mm	EI 120	rigid floors ≥ 150 mm	10 mm	25 mm	2 sides	-	121 mm	U/C + C/C	

<sup>1)</sup> Penetration services must be supported; support distance ≤ 500mm (wall) or ≤ 400mm (floor).

<sup>2)</sup> Constructive element must be classified acc. EN 13501-2 for the required fire resistance period. EI for flexible walls ≥ 100mm is also applicable for rigid walls ≥ 100mm!