

steel pipe in metal stud		0055	3
Fire Resistance Test In Accordance With EN 1366-3 / flex wall 100mm			
Steel pipe Ø 219,1 x 4,5 mm insulated by 25 mm Rockwool 810 LS 700 mm	with Firetect Graphite 10 x 25 mm (wxd) from both sides	EI 90 minutes	
aperture Ø 289 mm		C/U	

