

 cable bundle in metal stud		0154	23E
Fire Resistance Test In Accordance With EN 1366-3 / metal stud 100mm			
Cable bundle Ø 110 mm (50x 14 mm)	with Firetect Graphite 30 x 25 mm (wxd)	EI 120 minutes	
aperture Ø 170 mm	and 25 mm mineral wool backing from both sides		

