

PP in aerated concrete floor		0195	6.1
Fire Resistance Test In Accordance With EN 1366-3			
PP Pipe Ø 110 x 2,7 mm	with Firetect Graphite sealant 15x25 mm (wxd) on both sides	EI 90 minutes	
aperture Ø 140 mm			

