

| | | | |
|--|---|----------------------|---|
| copper pipe in metal stud | | 0208 | 7 |
| Fire Resistance Test In Accordance With EN 1366-3 / flex wall 100mm | | | |
| Copper pipe Ø 35 mm x 1,5 mm insulated by 25 mm Armaflex AF / 700 LS | with Firetect Graphite sealant 10 x 25 mm (wxd) from both sides | EI 90 minutes | |
| aperture Ø 98 mm | | C/U | |

