

PP pipe in metal stud

0245

44

Fire Resistance Test In Accordance With EN 1366-3 / flex wall 100mm

PP pipe Ø 125 x 3,1 mm

with Firetect FMU collar Ø 125 mm on both sides onto box of Firetect PA board 2S 50 mm

EI 90 minutes

aperture Ø 125 mm

and smoke seal Firetect Acrylic from both sides

U/C

