

fire damper in metal stud - principle configuration

0321

Fire Resistance Test In Accordance With EN 1366-2 / flex wall 100mm

fire damper
600 x 300 mm

SMOKE resistance acc. EN 1634-3: Sa - S200
with Firetect PA board 2S 50mm

EI 60 minutes

and Firetect Acrylic 5x25 mm on both sides

