

fire damper in metal stud - principle configuration

0325

Fire Resistance Test In Accordance With EN 1366-3 / flex wall 100mm

fire damper
600 x 300 mm

SMOKE resistance acc. EN 1634-3: Sa - S200
with Firetect PA board
and Firetect Acrylic 5x25 mm

EI 90 minutes

and Firetect Acrylic 5x25 mm on both sides and onto fire damper

