

PE pipe in metal stud

7.13

Fire Resistance Test In Accordance With EN 1366-3 / flex wall 100mm

PE Pipe Ø 250 x 9,6 mm

with Firetect FMU collar Ø 250mm +
smoke seal Firetect Acrylic on both sides

EI 60 minutes

on 2x 50mm PA board with PA screws

U/C

