

Copper pipe in aerated concrete floor		8.3.1
Fire Resistance Test In Accordance With EN 1366-3 / aerated concrete floor 150mm		
Copper pipe Ø 12 x 1,0 mm	with Firetect Acrylic sealant 10 x 25 mm (wxd) from both sides	EI 120 minutes
aperture Ø 32 mm		C/U

